



RCRA COMPLIANCE AND ENFORCEMENT BRANCH
ENFORCEMENT CASE RECOMMENDATION

EPA ID NUMBER: 9000745

FACILITY NAME: PEPCO Benning Road
Fueling Station

CASE REVIEW OFFICER: Jan Szaro

DATE: July 21, 2010

FINDINGS OF INITIAL CASE REVIEW: Facility was inspected on June 9, 2010 by EPA Contractor. The report noted that the rectifier log for the impressed current CP system was not available and that there was no documentation of functionality testing of the PLLD for the one UST system.

DISPOSITION RECOMMENDATION: CLOSE

JUSTIFICATION FOR RECOMMENDATION: Contacted Fariba Mahvi of PEPCO on July 12, 2010. Ms. Mahvi provided additional information received on July 20, 2010 that included a copy of the rectifier log for the period of Feb 20, 2009 to the present and a copy of the most recent passing functionality test of the PLLD which was conducted on Aug 27, 2009.

CONCURRENCE SECTION

CASE REVIEW OFFICER

Jan Szaro

DATE: 7/21/10

TEAM LEADER

Melinda Poffel

DATE: 7/22/10

ASSOCIATE DIRECTOR

Carol Freund

DATE: 7/22/10